



DATE: JOB: PROJECT: TAG:

COMPANY: SALES PERSON: MXI-ARRANGEMENT- 4, LEVEL 2, VERTICAL DISCHARGE, MOUNTING RAIL



VERTICAL CEILING HUNG



q W ⊺→→

FOUNDATION PLAN VIEW

MOUNTING RAILS ARE NEEDED WHEN FAN WILL BE MOUNTED IN VERTICAL UPBLAST OR DOWNBLAST ARRANGEMENT EITHER CEILING HUNG OR BASE MOUNTED WITH USE OF ISOLATORS.

REPLACES:

- MOUNTING RAILS TO BE SHIPPED LOOSE WITH HARDWARE.
- **ISOLATORS ARE SUPPLIED AS PER ORDER**

VERTICAL BASE MOUNT

135 13 150 14 165 13 182 14 200 18	13 1/4 3 15/16 4 15/16 5 11/16 6 15/16	26 3/4 29 3/8 30 15/16 32	C3 x 4.1 C3 x 4.1 C3 x 4.1	1 45T 1 45T 1 45T	180 214	181 213
150 14 165 13 182 16 200 18	4 15/16 5 11/16 6 15/16	30 15/16 32	C3 x 4.1		214	213
165131821620018	5 11/16 6 15/16	32		145T		213
182 1 a 200 18	6 15/16		<u> </u>	1401	250	254
200 18			C3 x 4.1	184T	285	290
	0 0/1/	33 15/16	C4 x 5.4	215T	352	357
222	8 3/16	35 3/4	C4 x 5.4	256T	426	430
	193/4	41	C5 x 6.7	256T	535	528
245	21 3/8	43 5/8	C6x 8.2	286T	636	632
270	23 1/8	46 1/4	C6x 10.5	326T	762	771
300 25	5 3/16	51 1/2	C6x 10.5	326T	937	927
330 23	27 5/16	54 3/4	C8x11.5	365T	1090	1102
365	29 3/4	60 1/4	C8x11.5	404T	1337	1334
402 🔇	32 3/8	66 1/4	C10x15.3	404T	1591	1549
445	35 3/8	71 7/8	C12x30	405T	1879	1825
490 38	8 9/16	80 3/16	C12x30	444T	2451	-
542 42	2 3/16	86 1/16	C12x30	445T	2903	-
600	46 1/4	96 1/8	C12x30	445T	3482	-

DIMENSIONAL DATA

FORM:

REVISION: PRINTED:3/4/2021

PRODUCT INFORMATION SUBJECT TO CHANGE WITHOUT NOTICE www.pennbarry.com