



DATE: TAG:
JOB:
PROJECT:
COMPANY:
SALES PERSON:

MXI - cULus Certifications,
All Arrangements

UL 705

ALL ARRANGEMENTS

- MXI carries the UL label, 705 Power Ventilators (ZACT, ZACT7): File #E256857

UL Heat and Smoke

ARRANGEMENT 9 (BELT DRIVE)

- Power Ventilators for Smoke-control Systems (ZAXH/ZAXH7), FILE #MH19473 (500F-6 hrs, 572F-2 hrs)
- Construction requirements:
 - High temperature paint, steel wheel, cooling wheel, belt tube, ceramic shaft seal, copper lube lines, life safety factor drive kit, Class F motor.

ARRANGEMENT 4 (DIRECT DRIVE)

- Power Ventilators for Smoke-control Systems (ZAXH/ZAXH7), FILE #MH19473 (500F-6 hrs, 572F-2 hrs, 1000F-1 hr)
- Construction requirements:
 - High temperature paint, cooling tube, copper lube lines, Class H motor.

UL 762, Restaurant Grease Exhaust

ARRANGEMENT 9 (BELT DRIVE)

- Power Ventilators for Restaurant Exhaust Appliances (YZHW/ YZHW7), file #MH10684
- Max operating temperature 400°F
- Construction requirements:
 - Same as UL Heat and smoke, except add an access door, drain, inlet and outlet flange.

ARRANGEMENT 4 (DIRECT DRIVE)

- Power Ventilators for Restaurant Exhaust Appliances (YZHW), file #MH10684 (US only)
- Max operating temperature 300°F
- Construction requirements:
 - Same as UL Heat and smoke, except add an access door, drain, inlet and outlet flange.