


DATE: TAG:

JOB:
PROJECT:
COMPANY:
SALES PERSON:

UTILITY VENT SET FAN UVS2, CLASS 1 AND 2, BACKDRAFT DAMPER



MODEL	F											G
SIZES	100%	95%	90%	85%	80%	75%	70%	65%	60%	55%	50%	G
060	8.19	ı	ı	ı	ı	ı	ı	_	ı	-	ı	11.56
070	8.19	_	ı	ı	ı	-	-	_	ı	_	ı	11.56
080	8.19	-	-	-	-	-	-	-	-	-	-	11.56
105	8.19	-	-	-	-	-	-	-	-	-	-	11.56
122	9.88	9.75	9.56	9.44	9.25	9.06	-	-	-	-	-	13.06
135	10.88	10.75	10.56	10.38	10.19	10.00	9.81	-	-	-	-	14.38
150	12.06	11.88	11.69	11.50	11.31	11.06	10.88	10.69	10.50	-	-	15.88
165	13.25	13.06	12.81	12.63	12.44	12.19	11.94	11.75	11.50	11.31	_	17.56
182	14.06	13.88	13.63	13.38	13.06	12.88	12.63	12.38	12.13	11.88	11.63	20.06
200	15.38	15.13	14.88	14.63	14.38	14.13	13.88	13.50	13.25	13.00	12.75	22.00
222	17.13	16.88	16.63	16.25	16.00	15.75	15.38	15.13	14.75	14.50	14.13	24.50
245	18.75	18.50	18.13	17.88	17.50	17.13	16.88	16.50	16.13	15.88	15.63	27.00
270	20.63	20.38	20.00	19.63	19.38	18.88	18.50	18.13	17.75	17.38	17.13	29.75
300	23.00	22.63	22.25	21.88	21.50	21.00	20.63	20.25	19.88	19.38	19.13	32.88
330	25.25	24.88	24.38	24.00	23.63	23.13	22.63	22.25	21.75	21.38	21.00	36.19
365	27.88	-	-	-	26.13	-	-	-	-	-	23.25	40.06
402	30.75	-	-	-	28.88	_	-	-	_	-	25.63	44.13
445	34.00	_	-	ı	31.88	_	_	_	ı	_	28.25	48.75
490	37.50	_	_	1	35.13	_	_	_	-	_	31.13	53.50
542	41.50	-	-	-	38.88	-	-	_	-	-	34.50	59.19
ALL DIMEN	ISI <u>ons</u> Af	SE IN INC	CHES									

REVISION: FORM: REPLACES: